

**INSPECTION CERTIFICATE**

**Date: 23/02/2017**

**FILE NO. 17.13228**

**COMPLIANCE  
With IEC 61508**

**SGS Italia Spa  
hereby confirm that**

**T.E.R. Tecno Elettrica Ravasi Srl  
Calco (LC)  
Via Privata Garibaldi 29/31**

**Limit switches model  
FOX**

**MEET THE SIL REQUIREMENTS DETAILED IN THE ANNEXED TABLE  
CAN BE USED UP TO SIL1 FOR THE SAFETY FUNCTION:  
"operation/control on demand"**

**FOR PRODUCTS TYPE A  
LOW DEMAND MODE**

**Technical report: 17.500.0115 dtd. 23/02/2017 and 14.500.0045 dtd. 31/01/2014  
Reference standard: IEC 61508:2010, part 2,4,6,7**

**Expiry date : 23/02/2020**



Member of SGS (Société Générale de Surveillance) Group

This document is issued by the Company under its General Conditions of Service accessible at [http://www.sgs.com/terms\\_and\\_conditions.html](http://www.sgs.com/terms_and_conditions.html). Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein relates to the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not constitute a warranty or a statement of fact. Any unauthorized alteration, copying or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. The Sign stamp and signature merely represent receipt of the document and SGS makes no representation as to the accuracy, adequacy and/or completeness of third party test laboratory results, reports or certifications. Any holder of this document is advised that the information contained herein is limited to visual examination of the safety and readily accessible portions of the equipment only. Safety for services related to activities involving a third party's intervention(s) in accordance with Client's instructions, the Company's involvement has been limited to witnessing/observing a third party's intervention(s) at the third party's laboratory/ test house or other facilities and installations used for the intervention(s). The Company's sole responsibility was to be present at the time of the third party's intervention(s) to forward the results, or confirm the documents, of the intervention(s). The Company is not responsible for the condition or calibration of apparatus, instruments and measuring devices used, the analysis methods applied, the qualifications, actions or competence of the third party's personnel or the analysis results.

**SUMMARY TABLE**

E/E/PE system Function definition	Limit switches mod. FOX operation on demand
Max SIL	SIL1
SFF	60%
$\lambda_{DU}$	4000 FIT
DC	50%
PFDavg	1,75E-2
HFT	0
MTBF	57 years
MTTR	24 hours
Proof test interval	1 year
Mission Time	10 years

Technical and Operation Manger  
Renato Donadel

This certificate is composed of 2 pages



Member of SGS (Société Générale de Surveillance) Group

This document is issued by the Company under its General Conditions of Service accessible at: [http://www.sgs.com/terms\\_and\\_conditions.htm](http://www.sgs.com/terms_and_conditions.htm). Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not constitute evidence of a warranty from external third parties and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. The SGS stamp and signature merely represents receipt of the document and SGS makes no representation as to the accuracy, adequacy and/or completeness of third party test/laboratory results, reports or recommendations. Any holder of this document is advised that the information contained herein is limited to visual examination of the safety and security hardware portfolio of the client's equipment only. Safety for services related to wireless (including a third party's intervention) in accordance with Client's instructions, the Company's involvement has been limited to witness (including a third party's intervention) at the third party's workplace (not home or other facilities and qualifications used for the intervention). The Company's sole responsibility was to be present at the site of the third party's intervention to forward the results, or confirm the accuracy, of the interventionist. The Company is not responsible for the condition or calibration or apparatus, instruments and measuring devices used, the analysis methods applied the qualifications, actions or decisions of the third party's personnel or the analysis results.